

ORDINANCE NO. 11233 FEB 12 1974
(New Series)

AN ORDINANCE AMENDING CHAPTER IX, ARTICLE 7,
OF THE SAN DIEGO MUNICIPAL CODE BY ADDING
SECTIONS 92.0726 AND 92.0727, RELATING TO THE
CITY'S ELECTRICAL REGULATIONS.

BE IT ORDAINED, by the Council of The City of San Diego,
as follows:

Section 1. That Section 92.0726 of the San Diego
Municipal Code, be and the same is hereby added to read as
follows:

SEC. 92.0726 SECTION 210-7 OF THE NATIONAL
ELECTRICAL CODE AMENDED

Section 210-7. Grounding-Type Receptacles and
Protection. Receptacles and cord connectors equipped
with grounding contacts shall have those contacts
effectively grounded. The branch-circuit or branch-
circuit raceway shall include or provide a grounding
conductor to which the grounding contacts of the
receptacle or cord connector shall be connected.
Acceptable grounding means are outlined in Section
250-91(b).

Exception: For extensions only in existing
installations which do not have a grounding conductor
in the branch circuit, the grounding conductor of a
grounding-type receptacle outlet may be grounded to a
grounded cold water pipe near the equipment.

MICROFILMED

MAY 2 1978

00641

All 15- and 20-ampere receptacle outlets on single-phase circuits for construction sites shall have approved ground-fault circuit protection for personnel. This requirement shall become effective when adopted by the California State Occupational Safety and Health Administration.

Section 2. That Section 92.0727 of the San Diego Municipal Code, be and the same is hereby added to read as follows:

SEC. 92.0727 SECTION 370-3 OF THE NATIONAL ELECTRICAL CODE AMENDED

Section 370-3. Nonmetallic Boxes. Nonmetallic boxes approved for the purpose may be used only with open wiring on insulators, concealed knob-and-tube work, nonmetallic-sheathed cable, and with approved nonmetallic conduit. The use of nonmetallic boxes shall be limited to single-family residential buildings and multi-family residential buildings two stories or less in height.

Section 3. This ordinance shall take effect and be in force on the thirtieth day from and after its passage.

APPROVED: JOHN W. WITT, City Attorney

By



William S. Shaffran, Deputy

p/1-15-74

MICROFILMED 11233

MAY 2 1978

C0642

Passed and adopted by the Council of The City of San Diego on FEB 12 1974
 by the following vote:

Councilmen	Yeas	Nays	Excused	Absent
Gil Johnson	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Maureen F. O'Connor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lee Hubbard	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leon L. Williams	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Floyd L. Morrow	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Bob Martinet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Jim Ellis	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Jim Bates	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Mayor Pete Wilson	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

AUTHENTICATED BY:

PETE WILSON
 Mayor of The City of San Diego, California.

EDWARD NIELSEN
 City Clerk of The City of San Diego, California.

(Seal)

By Yolanda Lino, Deputy.

I HEREBY CERTIFY that the foregoing ordinance was not finally passed until twelve calendar days had elapsed between the day of its introduction and the day of its final passage, to wit, on

JAN 29 1974

FEB 12 1974

~~I FURTHER CERTIFY that said ordinance was not finally passed until twelve calendar days had elapsed between the day of its introduction and the day of its final passage, to wit, on~~

I FURTHER CERTIFY that the reading of said ordinance in full was dispensed with by a vote of not less than a majority of the members elected to the Council, and that there was available for the consideration of each member of the Council and the public prior to the day of its passage a written or printed copy of said ordinance.

EDWARD NIELSEN
 City Clerk of The City of San Diego, California.

(Seal)

By Yolanda Lino, Deputy.

RECEIVED
 CITY CLERK'S OFFICE
 1974 JAN 16 AM 11:05
 SAN DIEGO, CALIF.

MICROFILMED

MAY 2 1978

Office of the City Clerk, San Diego, California	
Ordinance Number <u>11233</u>	Adopted <u>FEB 12 1974</u>

RECEIVED
CITY CLERK'S OFFICE

ATTORNEY (S)

1974 MAR 22 AM 9:23 *eg*

SAN DIEGO, CALIF.

CITY OF SAN DIEGO,
202 "C" St.,
12th Floor,
San Diego, CA.

CERTIFICATE OF PUBLICATION

No.

IN THE MATTER OF

CITY'S ELECTRICAL REGULATIONS

MAR 22 1974 *eg*

I, Patricia M. Applestill hereby certify that San Diego Daily Transcript is a daily newspaper of general circulation within the provisions of the Government Code of the State of California, printed and published in the City of San Diego, County of San Diego, State of California; that I am the principal clerk of said newspaper; that the

ORDINANCE NO. 11233
(New Series)

is a true and correct copy of which this certificate is annexed and was published in said newspaper on

February 21, 1974

I certify under penalty of perjury that the foregoing is true and correct, at San Diego, California, on

March 18, 1974

Patricia M. Applestill

(Signature)

9" @ 4.42

39.78 *eg*

C0644

ORDINANCE NO. 1123

(New Series)

AN ORDINANCE AMENDING CHAPTER IX, ARTICLE 7, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTIONS 92.0726 AND 92.0727, RELATING TO THE CITY'S ELECTRICAL REGULATIONS, BE IT ORDAINED, by the Council of The City of San Diego, as follows:

Section 1. That Section 92.0726 of the San Diego Municipal Code, be the same is hereby added to read as follows:

SEC. 92.0726 SECTION 210-7 OF THE NATIONAL ELECTRICAL CODE AMENDED

Section 210-7. Grounding Type Receptacles and Protection. Receptacles and cord connectors equipped with grounding contacts shall have those contacts effectively grounded. The branch-circuit or branch-circuit raceway shall include or provide a grounding conductor to which the grounding contacts of the receptacle or cord connector shall be connected. Acceptable grounding means are outlined in Section 250-01(b).

Exception: For extensions only in existing installations which do not have a grounding conductor in the branch circuit, the grounding conductor of a grounding-type receptacle outlet may be grounded to a grounded cold water pipe near the equipment.

All 15- and 20-ampere receptacle outlets on single-phase circuits for construction sites shall have approved ground-fault protection for personnel. This requirement shall become effective when adopted by the California State Occupational Safety and Health Administration.

Section 2. That Section 92.0727 of the San Diego Municipal Code, be the same is hereby added to read as follows:

SEC. 92.0727 SECTION 370-3 OF THE NATIONAL ELECTRICAL CODE AMENDED

Section 370-3. Nonmetallic Boxes. Nonmetallic boxes approved for the purpose may be used only with open wiring on insulators, concealed knob-and-tube work, nonmetallic-sheathed cable, and with approved nonmetallic conduit. The use of nonmetallic boxes shall be limited to single-family residential buildings and multi-family residential buildings two stories or less in height.

Section 3. This ordinance shall take effect and be in force on the thirtieth day from and after its passage.

Introduced on January 22, 1974.

Passed and adopted by the Council of The City of San Diego on February 12, 1974.

AUTHENTICATED BY: PETE WILSON
Mayor of The City of San Diego, California.
EDWARD NIELSEN,
City Clerk of The City of San Diego, California.
By YOLANDA LINDOR, Deputy

C0645