

(0-93-155)

ORDINANCE NUMBER O- 17927 (NEW SERIES)

ADOPTED ON JUN 01 1993

AN ORDINANCE AMENDING CHAPTER V, ARTICLE 5, DIVISION 3, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0310.0401; BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 4, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0425.0502; AND BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 7, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0780.0103 ALL RELATING TO THE UNIFORM FIRE CODE, 1991 EDITION.

WHEREAS, May 18, 1993, has been declared "Regulatory Relief Day"; and

WHEREAS, the purpose of Regulatory Relief Day is to streamline and consolidate where appropriate the City's regulatory procedures; and

WHEREAS, the Fire Department has reviewed the 1991 Edition of the Uniform Fire Code which this City has adopted in Chapter V, Article 5, of the San Diego Municipal Code and has suggested adopting three (3) sections of the 1991 Uniform Fire Code with changes that will streamline the regulatory process; and

WHEREAS, the City Council of The City of San Diego finds and declares that the recommended additions to the San Diego Municipal Code incorporate changes and modifications reasonably necessary because of present local conditions; NOW, THEREFORE,

BE IT ORDAINED, by the Council of The City of San Diego, as follows:

Section 1. That Chapter V, Article 5, Division 3, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0310.0401, to read as follows:

SEC. 55.0310.0401 WATER SUPPLIES FOR FIRE PROTECTION

U.F.C. (1991 Edition) is adopted with changes to read as follows:

An approved water supply capable of supplying the required fire flow for fire protection shall be provided to all premises upon which facilities, buildings, or portions of buildings are hereafter constructed or moved into or within the jurisdiction. When any portion of the facility or building protected is in excess of three hundred (300) feet from a water supply on a public street, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the Fire Chief.

Section 2. That Chapter V, Article 5, Division 4, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0425.0502, to read as follows:

SEC. 55.0425.0502 DISPLAYS

U.F.C. 25.502 (1991 Edition) is adopted with changes to read as follows:

- (a) **General** - no change.
- (b) **Batteries** - no change.
- (c) **Fuel systems**

(1) **Fueling** - no change.

(2) **Quantity limit.** Fuel in the fuel tank shall not exceed one quarter of the tank capacity or five (5) gallons, whichever is less.

Exception: Fuel in a fuel tank which is classified as a combustible liquid shall not exceed one quarter of the tank capacity when vehicles containing such fuel are displayed in buildings fully protected with an automatic fire sprinkler system.

(3) **Inspection** - no change.

(4) **Closure** - no change.

(d) **Location** - no change.

Section 3. That Chapter V, Article 5, Division 7, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0780.0103, to read as follows:

SEC. 55.0780.0103 PERMITS

U.F.C. 80.103 (1991 Edition) is adopted with changes to read as follows:

(a) **General** - no change.

(b) **Hazardous Materials Management Plan** - no change.


(c) **Hazardous Materials Inventory Statement.** When required by the Fire Chief, each application for a permit shall include a Hazardous Material Inventory Statement ("HMIS").

Exception: If a HMIS is on file and there has been no inventory changes which would render the HMIS on record as inaccurate, then a new HMIS need not be submitted if

permittee signs a statement certifying that the HMIS on file is accurate.

Section 4. This ordinance shall take effect and be in force on the thirtieth day from and after its passage.

APPROVED: JOHN W. WITT, City Attorney

By 
Elmer L. Heap, Jr.
Deputy City Attorney

ELH:jrl
04/28/93
Or.Dept:Fire
O-93-155
Form=o+t

NEW LANGUAGE - SHADED
OLD LANGUAGE - STRIKEOUT

ORDINANCE NUMBER O- 17927 (NEW SERIES)

ADOPTED ON JUN 01 1993

AN ORDINANCE AMENDING CHAPTER V, ARTICLE 5, DIVISION 3, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0310.0401; BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 4, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0425.0502; AND BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 7, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0780.0103 ALL RELATING TO THE UNIFORM FIRE CODE, 1991 EDITION.

Section 1. That Chapter V, Article 5, Division 3, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0310.0401, to read as follows:

SEC. 55.0310.0401 WATER SUPPLIES FOR FIRE PROTECTION

U.F.C. (1991 Edition) is adopted with changes to read as follows:

An approved water supply capable of supplying the required fire flow for fire protection shall be provided to all premises upon which facilities, buildings, or portions of buildings are hereafter constructed or moved into or within the jurisdiction. When any portion of the facility or building protected is in excess of three hundred (300) feet from a water supply on a public street, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the Fire Chief.

Section 2. That Chapter V, Article 5, Division 4, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0425.0502, to read as follows:

SEC. 55.0425.0502 DISPLAYS

U.F.C. 25.502 (1991 Edition) is adopted with changes to read as follows:

(a) **General - no change.**

(b) **Batteries - no change.**

(c) **Fuel systems**

(1) **Fueling - no change.**

(2) **Quantity limit. Fuel in the fuel tank shall not exceed one quarter of the tank capacity or five (5) gallons, whichever is less.**

Exception: Fuel in a fuel tank which is classified as a combustible liquid shall not exceed one quarter of the tank capacity when vehicles containing such fuel are displayed in buildings fully protected with an automatic fire sprinkler system.

(3) **Inspection - no change.**

(4) **Closure - no change.**

(d) **Location - no change.**

Section 3. That Chapter V, Article 5, Division 7, of the San Diego Municipal Code be and the same is hereby amended by adding Section 55.0780.0103, to read as follows:

BEC. 55.0780.0103 PERMITS

U.F.C. 80.103 (1991 Edition) is adopted with changes to read as follows:

(a) General - no change.

(b) Hazardous Materials Management Plan - no change.

(c) Hazardous Materials Inventory Statement. When required by the Fire Chief, each application for a permit shall include a Hazardous Material Inventory Statement ("HMIS").

Exception: If a HMIS is on file and there has been no inventory changes which would render the HMIS on record as inaccurate, then a new HMIS need not be submitted if permittee signs a statement certifying that the HMIS on file is accurate.

ELH:jrl
04/29/93
Or.Dept:Fire
0-93-155
Form=o+t

Passed and adopted by the Council of The City of San Diego on JUN 01 1993,
 by the following vote:

Council Members	Yeas	Nays	Not Present	Ineligible
Abbe Wolfsheimer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ron Roberts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
John Hartley	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
George Stevens	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tom Behr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Valerie Stallings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Judy McCarty	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Juan Vargas	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mayor Susan Golding	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

AUTHENTICATED BY:

(Seal)

SUSAN GOLDING
 Mayor of The City of San Diego, California.

CHARLES G. ABDELNOUR
 City Clerk of The City of San Diego, California.
 By [Signature], Deputy.

I HEREBY CERTIFY that the foregoing ordinance was not finally passed until twelve calendar days had elapsed between the day of its introduction and the day of its final passage, to wit, on MAY 18 1993, and on JUN 01 1993.

~~I FURTHER CERTIFY that said ordinance was read in full prior to its final passage.~~

I FURTHER CERTIFY that the reading of said ordinance in full was dispensed with by a vote of not less than a majority of the members elected to the Council, and that there was available for the consideration of each member of the Council and the public prior to the day of its passage a written or printed copy of said ordinance.

(Seal)

CHARLES G. ABDELNOUR
 City Clerk of The City of San Diego, California.
 By [Signature], Deputy.

Office of the City Clerk, San Diego, California	
Ordinance Number <u>0-17927</u>	Adopted <u>JUN 01 1993</u>

RECEIVED
CITY CLERK'S OFFICE
93 MAY -5 PM 4:58
SAN DIEGO, CALIF.

MAY 18 1993

MAY 19 1993

MAY 19 1993

50 L

CERTIFICATE OF PUBLICATION

RECEIVED
CITY CLERK'S OFFICE

93 JUN 16 AM 9:46

SAN DIEGO, CALIF.

OFFICE OF THE CITY CLERK
2ND FLOOR
CITY ADMINISTRATION BUILDING
202 C STREET
SAN DIEGO, CA 92101

IN THE MATTER OF

NO.

AN ORDINANCE AMENDING CHAPTER V, ARTICLE 5...

ORDINANCE NUMBER O-17927 (NEW SERIES)
AN ORDINANCE AMENDING CHAPTER V, ARTICLE 5, DIVISION 3, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0310.0401; BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 4, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0425.0502; AND BY AMENDING CHAPTER V, ARTICLE 5, DIVISION 7, OF THE SAN DIEGO MUNICIPAL CODE BY ADDING SECTION 55.0780.0103 ALL RELATING TO THE UNIFORM FIRE CODE, 1991 EDITION.
This ordinance amends Chapter V, Article 5, of the San Diego Municipal Code by adding three (3) sections to the San Diego Fire Code. This ordinance adopts three (3) sections of the U.F.C. (1991 Edition) with changes. The following sections are added to the San Diego Municipal Code:
Section 55.0310.0401 adopts U.F.C. section 10.401 with changes pertaining to the number of fire hydrants required on certain premises.
Section 55.0425.0502 adopts U.F.C. section 25.502 with changes pertaining to fuel tank capacity for vehicles used for display purposes in buildings.
Section 55.0780.0103 adopts U.F.C. section 80.103 with changes pertaining to the annual submittal of the Hazardous Material Inventory Statement by a permittee.
A complete copy of the ordinance is available for inspection in the office of the City Clerk of the City of San Diego, second floor, City Administration Building, 202 "C" Street, San Diego, CA 92101.
INTRODUCED ON MAY 18 1993
Passed and adopted by the Council of the City of San Diego on JUN 01 1993.
AUTHENTICATED BY:
SUSAN GOLDING
Mayor of The City of San Diego, CA
CHARLES G. ABDELNOUR
City Clerk of The City of San Diego, CA
By Suzanne Oliva, Deputy
Pub. June 15 274907

I, Corey Donahue, am a citizen of the United States and a resident of the county aforesaid; I am over the age of eighteen years, and not a party to or interested in the above-entitled matter. I am the principal clerk of the San Diego Daily Transcript, a newspaper of general circulation, printed and published daily, except Saturdays and Sundays, in the City of San Diego, County of San Diego and which newspaper has been adjudged a newspaper of general circulation by the Superior Court of the County of San Diego, State of California, under the date of January 23, 1909, Decree No. 14894; and the

ORDINANCE NUMBER O-17927 (NEW SERIES)

is a true and correct copy of which the annexed is a printed copy and was published in said newspaper on the following date(s), to wit:

JUNE 15

I certify under penalty of perjury that the foregoing is true and correct.

Dated at San Diego, California this 15th day of JUNE, 1993.

Corey Donahue
(Signature)

3 1/2" x 2 = \$ 92.16