

(R-96-227 REV.)

RESOLUTION NUMBER R-286760

ADOPTED ON DECEMBER 5, 1995

WHEREAS, San Diego Municipal Code section 55.0310.0501 requires the installation of fire sprinklers in highrise buildings including the City Administration Building on or before January 1, 1996; and

WHEREAS, the estimated cost of providing an automatic fire sprinkler system in the City Administration Building is \$7.5 million; and


WHEREAS, the Municipal Code authorizes an exemption from the sprinkler requirement where a commitment is made by a building owner to demolish a structure before January 1, 2000; and

WHEREAS, the City's conceptual program for new offices anticipates the vacation of the City Administration Building within the time frame of the January 1, 2000 deadline; NOW, THEREFORE,

BE IT RESOLVED, by the Council of The City of San Diego, that the City Council hereby expresses its intent to take actions and allocate funds as necessary to allow for the City

Administration Building to be brought into compliance with the ordinance's requirements or demolish or vacate the building by January 1, 2000.

APPROVED:  JOHN W. WITT, City Attorney

By   
Elmer L. Heap, Jr.  
Deputy City Attorney

HOV:ELH:ps:smf  
09/01/95  
12/01/95 COR. COPY  
12/19/95 REV.  
Or.Dept:REA/Clerk  
R-96-227