

ORDINANCE NUMBER O- 19254 (New Series)

ADOPTED ON JAN 13 2004

AN ORDINANCE OF THE COUNCIL OF THE CITY OF SAN DIEGO AMENDING CHAPTER 5, ARTICLE 5, DIVISION 10, OF THE SAN DIEGO MUNICIPAL CODE BY AMENDING SECTION 55.1003, PERTAINING TO FIRE PROTECTION AND PREVENTION.

BE IT ORDAINED, by the Council of the City of San Diego, as follows:

Section 1. That Chapter 5, Article 5, Division 10, of the San Diego Municipal Code is amended by amending Section 55.1003, to read as follows:

§55.1003 Fire Extinguishing Systems

1003.1 through 1003.2.11.7 [No change.]

1003.2.11.8 Violations:

- (a) [No change.]
- (b) It is unlawful for any owner of a high-rise building to allow any person to occupy any portion of a high-rise building after January 1, 2008, where occupancy has been authorized pursuant to section 55.1003.2.11.8(a)(4), except where: (1) the occupant is performing minimal maintenance to prevent the high rise building from being in an unsafe condition; or (2) the occupant is performing construction or maintenance to the building related to the installation or maintenance of an automatic fire sprinkler

system; or (3) an approved fire sprinkler system has been completely installed.

1003.3 [No change.]

Section 2. That a full reading of this ordinance is dispensed with prior to its final passage, a written or printed copy having been available to the City Council and the public a day prior to its final passage.

Section 3. This ordinance shall take effect and be in force on the thirtieth day from and after its passage.

APPROVED: CASEY GWINN, City Attorney

By



Susan Y. Cola
Deputy City Attorney

SYC:sc
12/01/03
12/02/03 COR.COPY
Or.Dept: E&CP
Aud.Cert: N/A
O-2004-78