

Article 5: Fire Protection and Prevention

Division 5: Fire Service Features

(“Fire Service Features” added 4-8-2008 by O-19728 N.S.)

§55.0501 Fire Service Features

501.1 Scope through 504.4 Roof access. Sections 501.1 through 504.4 of the California Fire Code have been adopted without change pursuant to section 55.0101(a).

*(“Fire Service Features” added 4-8-2008 by O-19728 N.S.; effective 5-8-2008.)
(Amended 7-31-2012 by O-20188 N.S.; effective 8-30-2012.)
(Amended 4-6-2016 by O-20625 N.S.; effective 5-6-2016.)*

§55.0505 Premises Identification

- (a) 505.1 Address identification. New and existing buildings shall have approved address numbers, building numbers, or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. For buildings used exclusively for residential purposes complying with the California Residential Code, such numbers shall be a minimum of 4 inches (101.6 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). For all other buildings, such numbers shall be a minimum of 6 inches (152.4 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). Where required by the *Fire Code Official*, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained by the property owner.
- (b) 505.2 Street or road signs through 507.5.6 Physical protection. Sections 505.2 through 507.5.6 of the California Fire Code have been adopted without change pursuant to section 55.0101(a).

*(“Premises Identification ” added 7-31-2012 by O-20188 N.S.; effective 8-30-2012.)
(Amended 1-18-2018 by O-20896 N.S.; effective 2-17-2018.)*

§55.0507 Fire Protection Water Supplies

507.5.7. Fire protection equipment and fire hydrants shall be clearly identified in a manner approved by the *Fire Code Official* to prevent obstruction by parked vehicles and other obstructions. When required by the *Fire Code Official*, hydrant locations shall be identified by the installation of reflective blue colored markers. Such markers shall be affixed to the roadway surface, approximately centered between curbs, and at a right angle to the hydrant.

(“Fire Protection Water Supplies” added 7-31-2012 by O-20188 N.S.; effective 8-30-2012.)

(Amended 4-6-2016 by O-20625 N.S.; effective 5-6-2016.)

(Amended 1-18-2018 by O-20896 N.S.; effective 2-17-2018.)

§55.0508 Fire Command Center

508.1 General through 510.1 Emergency responder radio coverage in new buildings. Sections 508.1 through 510.1 of the California Fire Code have been adopted without change pursuant to section 55.0101(a).

(“Fire Command Center” added 1-18-2018 by O-20896 N.S.; effective 2-17-2018.)

§55.0510 Emergency Responder Radio Coverage

510.3 Permit required through 510.6.3 Field testing. Sections 510.3 through 510.6.3 of the California Fire Code have been adopted without change pursuant to section 55.0101(a).

(“Emergency Responder Radio Coverage” added 1-18-2018 by O-20896 N.S.; effective 2-17-2018.)